


Flexible Operation of Post-Combustion Amine-based CCS with a Co-located Wind Farm

Rubenka Bandyopadhyay & Dalia Patiño-Echeverri
Nicholas School of the Environment
Duke University

FERC, Washington, D.C., November 7, 2014

Location of Coal Plants Suitable for CCS Retrofit



Map generated based on data from eGrid Database: <http://www.epa.gov/cleanenergy/energy-resources/egrid/>

~35% of electricity sector CO₂ emissions come from plants suitable for CCS retrofits

Wind power (~11 TW) could cost effectively meet RPS goals if challenges from intermittency and access to transmission capacity are resolved

Research Question

Can flexible operation of coal plants with CCS retrofits reduce:

- a) Cost of Capture of CO₂ (CoC)**
- b) Cost of integration of wind power**

Background
Information and
Objectives

Method

Partial Capture

Amine Storage

Conclusions

The Hybrid System



<http://blog.cleanenergy.org/2012/11/13/>

Supply to the grid
 via already
 existing
 transmission lines



<http://reneweconomy.com.au>

Post-combustion
 amine based CCS
 unit with partial
 capture [\(Slide\)](#)

OR

Post-combustion
 amine based CCS
 unit with amine
 storage capabilities
[\(Slide\)](#)



Method

- Choose an existing coal plant location suitable for the hybrid system¹
- Determine optimal size and dispatch schedule of the hybrid system to maximize revenue
- Measure hybrid system's performance:
 - Wind power integrated (MW) as % of nameplate capacity
 - Levelized cost of electricity (\$/MWh)
 - Cost of CO₂ Capture (\$/ton)
- Analysis of performance of the hybrid system in selected region for:
 - Electricity prices variability
 - Emissions rate limits (Imposed by regs. to Partial Capture)
 - Wind variability

1. Finkenrath M., Smith J., and Volk D. "CCS Retrofit: Analysis of the Globally Installed Coal-fired Power Plant Fleet". *International Energy Agency Information Report*. 2012

LP Optimization Model

Maximize

- $\Omega(\text{Net Revenue}) =$
 $\text{Revenue}_{\text{Coal Plant and Wind Farm}} - \text{Loss of Revenue}_{\text{CCS}} - \text{O\&M}_{\text{Coal}} -$
 $\text{Capital and O\&M Cost}_{\text{Wind Farm}} - \text{Variable Cost}_{\text{CCS}} -$
 $\text{Fixed Cost}_{\text{Amine Storage Configuration of CCS}}$

Decision Variables

- Size of Wind Farm
- Dispatch schedule of wind and coal unit
 - Partial capture \rightarrow amount of flue gas vented
 - Amine storage \rightarrow size of storage tank and rate of regeneration

Subject to physical constraints on operation of the hybrid system

Background
Information and
Objectives

Method

Partial
Capture

Amine
Storage

Conclusions

Data and Assumptions

- Perfect foresight for electricity price and wind speed forecasts
- Hourly electricity prices from PJM hubs year 2013
- 10-minutes synthetic wind power data from SynTiSe MCMC trained with EWITS data
- Capital costs of amine-storage from IECM (Integrated Environmental Control Model)
- No additional capital costs for partial capture
- Cost of wind power: NREL report '2011 Cost of Wind Energy Review'
- Coal plant specifications as in eGrid for Powerton (1786 MW plant)

Background
Information and
Objectives

Method

Partial Capture

Amine Storage

Conclusions

Metrics of performance

Cost of CO₂ Capture (\$ per ton) =

$$\frac{\text{LCOE}_{\text{Hybrid System}} - \text{LCOE}_{\text{Coal Plant without CCS}}}{\text{CO}_2\text{Emissions}_{\text{Coal Plant without CCS}} - \text{CO}_2\text{Emissions}_{\text{Hybrid System}}}$$

Levelized Cost of Electricity (LCOE in \$ per MWh) =

$$\frac{\text{Capital \& Annual Operating Cost}_{\text{Wind Farm}} + \text{Capital \& O\&M Cost}_{\text{CCS}} + \text{Loss of Revenue}_{\text{CCS}} + \text{O\&M Cost}_{\text{Coal Plant}}}{\text{Net Power Dispatched by the Hybrid System}}$$

Background
 Information and
 Objectives

Method

Partial Capture

Amine Storage

Conclusions

Quantifying Ramp Characteristics in Wind Power

To characterize wind power variability the following metrics are defined:

- $Ramp_t = I_{|WP_t - WP_{t-1}| \geq \text{Threshold}} * |WP_t - WP_{t-1}|$ where I is the indicator function
- Aggregated Ramp Magnitude: $Ramp_{t_0, d_{t_0}}^{\text{aggregated}} = |WP_{t_0} - WP_{t_0 + d_{t_0}}|$
- Average Ramp Magnitude: $Ramp_{t_0, d_{t_0}}^{\text{Rolling Avg}} = \frac{\sum_{i=t_0}^{t_0 + d_{t_0}} Ramp_i}{d_{t_0}}$
- Mean Aggregated Ramp Magnitude as Percentage:


$$MARMAP = \frac{\sum_{i \in I} Ramp_{t_i, d_{t_i}}^{\text{Rolling Avg}}}{\text{Nameplate Capacity} * |I|} * 100\%$$

where I is the index set of all aggregated ramp start instances [Example](#)

Area of Study: PJM

- Wind Power Variability in the Region

- ~ 12% % of total wind-sites in PJM in each ramp category



[Slide 16](#)




Results

Assuming the hybrid system is required to perform as a **base-load plant**:


- Configuration (how much wind?)
 - Cost of CO₂ capture
- For partial capture
 - For amine -storage
- Sensitivity to variability in prices and wind



Wind Power Integration for Base-load Operation




Cost of Capture (CoC) for Base-load Operation with Partial Capture Configuration



Base Case CoC : operation of a hybrid system with partial capture operation consisting of a 1785.6 MW sub-critical coal plant (with specs similar to the Powerton plant in IL), operating at the Chicago Hub with mid-level wind Power ramp characteristics. Annual average CO₂ emission limit: 300 lbs/MWh ([Slide 17](#))



Cost of Capture (CoC) for Base-load Operation with Amine Storage Configuration




Base Case CoC : operation of a hybrid system with amine storage operation consisting of a 1785.6 MW sub-critical coal plant (with specs similar to the Powerton plant in IL), operating at the Chicago Hub with mid-level wind Power ramp characteristics ([Slide 17](#))







Cost of Capture (CoC) for Base-load Operation with Amine Storage Configuration




Base Case CoC : Operation of a hybrid system with amine storage operation consisting of a 1785.6 MW sub-critical coal plant (with specs similar to the Powerton plant), operating at the Chicago Hub with mid-level wind power ramp characteristics



Cost of Capture (CoC) for Base-load Operation with Amine Storage Configuration



Base Case CoC : Operation of a hybrid system with amine storage operation consisting of a 1785.6 MW sub-critical coal plant (with specs similar to the Powerton plant), operating at the Dominion Hub with steady wind power ramp characteristics



Scope of Implementation for Partial Capture Configuration

- The potential for wind power integration depends on:
 - Variability of the wind power
 - Variability of electricity prices
- For PJM in 2013, the hybrid system's CoC is comparable to CoC for replacement with a new NGCC plant
- For highly variable wind (i.e. ramp >98%), base-load operation of hybrid system is not profitable

Scope of Implementation for Amine Storage Configuration

- The potential for wind power integration depends on:
 - Variability of the wind power
 - Variability of electricity prices
- Low price variability (e.g. AEP General Hub in 2013) does not allow cost-effective integration of wind for base-load power operation
- High price variability, (e.g. Dominion Hub in 2013), and ‘Steady’ wind, can integrate wind farms of capacities of up to 12.5%. If wind sites have ‘Mid Variability’ the wind farm size decreases to 2%
- Wind sites with “high” variability can not be profitably integrated with the hybrid system with base-load operation ([ramp characteristics](#))

Effect of relaxing the base-load operation constraint

- Increase in percent of wind power in the system ↑
- Reductions in the CoC values for both the partial capture and amine storage configurations. ↓
- Partial capture (net power allowed to vary beyond 10% of rated capacity) :
 - 5-21% increase in wind power integration
 - 1.5 – 4.2 \$/ton decrease in CoC is
- Amine Storage (net power allowed to vary beyond 10% of rated capacity) :
 - 18-32 % increase in wind power integration
 - 2-10.7 \$/ton decrease in CoC

Conclusions

- Provides a viable method of transitioning to a power system with **lower carbon emissions**
- Facilitates **renewable power integration**
- Provides a **hedge against uncertainty of natural gas prices and carbon emissions constraints**
- Allows significant **increase in profits relative to a CCS retrofitted coal plant operating continuously**
- For the amine storage configuration, the hybrid system has lower CoC relative to new NGCC plants if natural gas prices are at least:
 - ‘Steady’ wind and high price variability: **5.8 \$/MBtu**
 - Low price variability (e.g. AEP hub): **14.5 \$/MBtu**

Conclusions

- At least three additional benefits have not been considered:
 - Avoided costs of procuring additional transmission capacity for wind power: **Median value estimated at 15\$/MWh¹**
 - Avoided costs of integration of intermittent resources to the grid: Estimated at **3.10 – 5.13 \$/MWh** for up to 30% of penetration of wind power in the Eastern Interconnect²
 - Increased ramp-capability of the hybrid system: Analysis of our test system operation indicates ramp-capability payments of **110-430 \$/MW** to enable the system to operate without losses even in the absence of price variability

1. Mills A., Wiser R., and Porter K. "The Cost of Transmission of Wind Energy: A Review of Transmission Planning Studies". Renewable and Sustainable Energy Reviews 16 (2012) 1–19
2. "Eastern Wind Integration & Transmission Study", prepared by EnerNex Corporation for the National Renewable Energy Laboratory, February 2011

Questions?

Contact Information:

Rubenka Bandyopadhyay: rb171@duke.edu

Dalia Patiño-Echeverri: dalia.patino@duke.edu

Background
Information and
Objectives


Method

Partial Capture

Amine Storage


Conclusions

Flexible Operation of Post-Combustion Amine based CCS



Brasington R.D. Integration and Operation of Post-Combustion Capture System on coal-fired power generation: Load following and Peak Power. MS Thesis at MIT. June, 2012 [Previous Slide](#)

Location of Coal Plants Suitable for CCs Retrofit



[Return to Slide 2](#)

Background
Information and
Objectives


Method

Partial Capture

Amine Storage

Conclusions

Back-up Slide: CCS Legislation in the US



Carbon Capture & Storage in the States. <http://www.ncsl.org/research/energy/carbon-capture-and-storage-in-the-states.aspx> . Accessed 14th March, 2014.

Background
Information and
Objectives

Method


Partial Capture

Amine Storage

Conclusions

Back-up Slide:

Wind Power Potential in the US



Background
Information and
Objectives

Method


Partial Capture

Amine Storage

Conclusions

Back-up Slide

Quantifying Variability of Electricity Prices (LMP)




Back-up Slide

Quantifying Variability of Electricity Prices (LMP)

Hub Name	Mean Annual PD ^{Rolling Avg} (\$/MWh)	Mean Annual PD _t	$\frac{\sum_{i=1}^{8760} d_i}{8760}$	Standard Deviation (LMP _t)
'AEP GEN HUB'	7.049	4.795	0.198	14.44
'OHIO HUB'	7.277	5.070	0.201	15.25
'AEP-DAYTON HUB'	7.644	5.196	0.200	15.76
'CHICAGO GEN HUB'	7.684	5.514	0.212	15.37
'N ILLINOIS HUB'	7.875	5.680	0.213	15.92
'CHICAGO HUB'	8.210	6.002	0.213	16.88
'WEST INT HUB'	8.393	6.045	0.199	31.52
'ATSI GEN HUB'	8.501	6.481	0.198	73.35
'WESTERN HUB'	9.200	6.512	0.201	20.90
'EASTERN HUB'	9.439	7.010	0.203	23.27
'NEW JERSEY HUB'	9.553	7.031	0.203	23.55
'DOMINION HUB'	10.060	7.159	0.207	22.63

Quantifying Ramp Characteristics in Wind Power



Slide 8